



EMSL Analytical, Inc.

107 Haddon Avenue, Westmont, NJ. 08108 (856) 858-4800

Attn. Contact Person
Client: Business Name
Street Address
City, State Zipcode

EMSL Order: 370000000
Received: 01/01/09
Analysis Date: 01/08/09
Report Date: 01/08/09

Project: Water pipes

Detection of Iron-Related Bacteria in Water Samples with the IRB-BART™ System (EMSL Method: M121)

Lab Sample Number	Client Sample ID	Sample Location	Amount Analyzed	Iron-related Bacteria (Present/Absent)	Potential Population Size (CFU/mL)	Identification of Dominant Organism
0000-1	WT-01	Corroded pipe	10 mL	Present	100,000	Iron-related bacteria

EMSL maintains liability limited to cost of analysis. Interpretation of the data contained in this report is the responsibility of the client. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. The above test report relates only to the items tested. EMSL bears no responsibility for sample collection activities or analytical method limitations.

Dennis Kinney, Ph.D.
Laboratory Manager
or Approved EMSL Signatory