



# EMSL Analytical, Inc.

107 Haddon Avenue, Westmont, NJ. 08108 (856) 858-4800

**Attn.** Contact Person  
**Client:** Business Name  
Street Address  
City, State Zipcode

**EMSL Order:** 370000000  
**Received:** 01/01/09  
**Analysis Date:** 01/08/09  
**Report Date:** 01/08/09

**Project:** Water pipes

## Detection of Sulfate-Reducing Bacteria in Water Samples with the SRB-BART™ System (EMSL Method: M122)

Lab Sample Number	Client Sample ID	Sample Location	Amount Analyzed	Sulfate-reducing Bacteria (Present/Absent)	Potential Population Size (CFU/mL)	Identification of Dominant Organism
0000-2	WT-02	Corroded pipe	10mL	Present	10,000	Dense slime bacteria and SRB consortium

EMSL maintains liability limited to cost of analysis. Interpretation of the data contained in this report is the responsibility of the client. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. The above test report relates only to the items tested. EMSL bears no responsibility for sample collection activities or analytical method limitations.

Dennis Kinney, Ph.D.

**Laboratory Manager**

or Approved EMSL Signatory